# SHREVEPORT FIRE DEPARTMENT

## Fire Prevention Division

**505 Travis Street, Suite 510**
**Shreveport, Louisiana 71101**
**(318) 673-6740**

Fire Prevention requires routine maintenance on fire hydrants located on private property in accordance with NFPA 1 (2018) and NFPA 24 (2022).

Private water supply systems shall be tested and maintained in accordance with NFPA 25.

The center of a hose outlet shall not be less than 18 in. (450 mm) above final grade.

The center of a hose outlet shall not be more than 36 in. (900 mm) above final grade.

Hydrants on private property shall be serviced annually for your property to be provided with proper fire protection. For hydrant service, a licensed and bonded plumbing or fire protection company must be used. After work is completed, the property owner shall furnish Fire Prevention with documentation of the work performed.

Failure to comply with any of these requirements could be subject to fines not to exceed $500 per occurrence and/or a maximum jail sentence of 30 days.

For questions regarding this information contact Fire Prevention at 318-673-6740.


Fire Administration
263 N. Common Street
Shreveport, LA 71101
(318) 673-6650

Deputy Fire Chief
263 N. Common Street
Shreveport, LA 71101
(318) 673-6658

Assistant Chief
263 N. Common Street
Shreveport, LA 71101
(318) 673-6662

Communications
1144 Texas Avenue
Shreveport, LA 71101
(318) 675-2200
Fax (318) 675-2206

EMS
263 N. Common Street
Shreveport, LA 71101
(318) 673-6720
Fax (318) 673-6727

Maintenance
7300 Mansfield Road
Shreveport, LA 71109
(318) 673-6730
Fax (318) 673-6735

Prevention
505 Travis Street, Suite 510
Shreveport, LA 71101
(318) 673-6740
Fax (318) 673-6744

Training
6440 Greenwood Road
Shreveport, LA 71119
(318) 673-6766
Fax (318) 673-6769

www.shreveportfire.org